

CDG-002 INTERIM RESULTS 090712

CDG-002 Canon UPVC Tilt-turn - DG

ID	Name	Glazing Name	Glazing ID	U _w	SHGC _w	Tvis _w
1	CDG-002-001-01-4-20-4	4-20-4	3133	2.3	0.43	0.45
2	CDG-002-001-02-4Gy-20-4	4Gy-20-4	3134	2.3	0.32	0.28
3	CDG-002-002-01-4Sn-20Ar-4	4Sn-20Ar-4	10623	1.9	0.30	0.35
4	CDG-002-003-01-4-20Ar-4	4-20Ar-4	5185	2.2	0.43	0.45
5	CDG-002-003-02-4Gy-20Ar-4Gy	4Gy-20Ar-4Gy	5188	2.2	0.43	0.45
6	CDG-002-004-01-638Sx-18-4	638Sx-18-4	3140	2.3	0.40	0.45
7	CDG-002-005-01-638Sx-18Ar-4	638Sx-18Ar-4	5195	2.2	0.40	0.45
8	CDG-002-006-01-638CPGy-18Ar-4	638CPGy-18Ar-4	8773	1.8	0.24	0.20